

BUILDING SAFETY CERTIFICATE

No. 220/17104/26

Dated : 17/04/26

It is certified that the existing building BLOCK-1 (name of the building or premises) at Village- Harapur, Infovalley, Jatni, Khorda, Odisha (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	4	4	4	4	4	4 + Basement

The building is owned/occupied by **G D GOENKA PUBLIC SCHOOL, BHUBANESWAR** (name of the Institution) have complied with the Building safety requirements in accordance with National Building Code Rules and verified by the officers concerned of WORKS DEPARTMENT, GOVT. OF ODISHA (Name of Department/ Govt.) on 17.04.2026 (date of inspection) in the presence of Mr. Santosh Kumar Singh, Secretary, Flat No.- 304, Srikhetra Green Apartment, Patrapada, Bhubaneswar (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 17.04.2026 for a period of 3 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp and Railing has been provided for Physical Handicapped Students.
2. Staircase of 1.5mtr. width, riser – 0.15mtr. and tread of 0.30mtr. with three lifts have been provided.
3. Fire Fighting and Drinking Water facilities with Frist Aid Medical Facilities have been provided.
4. Ceiling height from floor to roof bottom is 3.5mtr. (11.50ft) and paved road available around the building for movement of fire vehicle.
5. All conditions of Building safety are satisfactory.

Issued on 17.04.2026 at Bhubaneswar by Mr. Rabindra Kumar Barik, Asst. Engineer.

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal:

Name:

Designation:

Name & Address of Department/Office:

BBSR R&B Section No.-I
Under Sub DIV No-IV/DIV No-II